



INSTITUT PRO TESTOVÁNÍ A CERTIFIKACI, a. s.
tř. T.Bati 299, 764 21 Zlín – Czech Republic
Testing Laboratory

Attest
No. 472101925

On sample:
pipe made from polyvinyl chloride (PVC), intended into the direct contact with drinking water, 63 x 4,7, PN 16, grey colour

Client:
La.re.ter. s.p.a.
25510622ia Occhiobello, 732, 45024 Fiesso Umbertiano, Rovigo, Italy
DIČ: IT01079200299

Values obtained and the assessment of the technical parameters:
Evaluated technical parameters of the leachates (see page 2 - 9) **meet hygienic requirements** of the article 3 paragraph 2 of the Decree of the Health Ministry No. 409/2005 Coll. *Hygienic requirements for articles intended to come into contact with water and for the water treatment* for articles intended into **the direct long time contact** with drinking water.

Evaluated sample does not negatively influence the sensorial properties of the drinking water.

Issued on: 20th July 2007
Valid till: 31st July 2010



Doc. Ing. Vladimír Klepal, CSc.
Head of the testing laboratory

*The results given in this Certificate apply only to the sample tested by our laboratory!
Without a written consent by Institut pro testování a certifikaci, a. s., Zlín,
the Certificate may not be reproduced unless as a whole!*
Page 1 (pages 12)